

CHAPTER 204
NEW INSTALLATIONS OF POWER BOILERS

[Prior to 9/24/86, Labor, Bureau of [530]]
[Prior to 1/14/98, see Labor Services[347] Ch 43]

875—204.1(89) Construction criteria.

204.1(1) *Installations— July 1, 1959, to June 30, 1996.* No power boiler shall be installed unless it has been designed, manufactured, inspected, installed, and stamped in accordance with the requirements of ASME Code for Boilers and Pressure Vessels Section I and has been registered with the National Board of Boiler and Pressure Vessel Inspectors.

204.1(2) *Installations after July 1, 1996.* No power boiler shall be installed unless it has been designed, manufactured, stamped, installed, and inspected to a recognized national or international standard such as ASME, German Institute of Standards (DIN), British Standards Institute (BSI), Japanese Industrial Standards (JIS), or Canadian National Standards, and has been registered with the National Board. Only national and international standards acceptable to the division of labor services may be utilized.

875—204.2(89) New installations.

204.2(1) *Installations— July 1, 1983, to December 31, 1988.* All new installations of boilers, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1986) with 1988 addenda. Boiler installations shall also comply with ANSI/ASME CSD-1 (1982), excluding the provisions for listing or labeling by a nationally recognized testing agency.

204.2(2) *Installations— January 1, 1989, to December 31, 1990.* All new installations of boilers, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1986) with 1988 addenda. Boiler installations shall also comply with ANSI/ASME CSD-1 (1988), excluding the provisions for listing or labeling by a nationally recognized testing agency.

204.2(3) *Installations— January 1, 1991, to June 30, 1995.* All new installations of boilers, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1989) with 1990 addenda. Boiler installations shall also comply with ANSI/ASME CSD-1 (1990), excluding the provisions for listing or labeling by a nationally recognized testing agency.

204.2(4) *Installations—July 1, 1996, to December 31, 1997.* All new installations between July 1, 1996, and December 31, 1997, of boilers, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1992 with 1994 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CNS. Gas-fired jacketed steam kettles may be installed provided they are designed, installed, inspected and stamped in accordance with ASME Code for Boilers and Pressure Vessels Section VIII, Division I, Appendix 19 (1995). Unfired steam boilers shall not be constructed under the provisions of Section VIII. Installations shall also comply with ANSI/ASME CSD-1 (1995 with 1996 addenda).

204.2(5) *Installations after January 1, 1998.* After January 1, 1998, all new installations of boilers, including reinstalled boilers, shall be installed in accordance with the requirements of the ASME Code for Boilers and Pressure Vessels Section I (1995 with 1997 addenda) or with the requirements of recognized national or international standards such as DIN, BSI, JIS, or CNS. Unfired steam boilers shall not be constructed under the provisions of Section VIII. Boiler installations shall also comply with ANSI/ASME CSD-1 (1995 with 1996 addenda).

[Filed 7/15/59]

[Filed 5/6/83, Notice 3/30/83—published 5/25/83, effective 7/1/83]

[Filed emergency 9/5/86—published 9/24/86, effective 9/24/86]

[Filed 3/17/89, Notice 9/21/88—published 4/5/89, effective 5/10/89]

[Filed 10/25/91, Notice 7/10/91—published 11/13/91, effective 1/1/92]

[Filed 5/16/96, Notice 11/22/95—published 6/5/96, effective 8/1/96]

[Filed emergency 12/26/97 after Notice 11/19/97—published 1/14/98, effective 1/1/98]